

**KEY**

BS 5837:2012 Tree Category

A B C U

**TREE CONSTRAINTS INFORMATION**

TAG Tree / Group Reference (by category)

Individual tree (by category)

Tree group/hedge (by category)

Root protection area - RPA (BS5837)

RPA Modified due to site conditions

Attenuation system

**TREE PROTECTION PLAN - DETAILS**

**Tree / Hedge Removal**

Tree to be removed

Section of hedge to be removed

**Arboricultural Method Statement/s**

All AMS areas are to be worked in strict accordance to detailed arboricultural method statements.

Special protection area - attenuation installation and works in RPA

AMS: a detailed Arboricultural Method Statement to be agreed with the LPA prior to commencement of development

**Construction Exclusion Zone/s**

Construction Exclusion Zone - CEZ

All operations inside of Tree Protective Fencing are to be supervised by an appointed arboriculturist.

**Tree protective barrier/s**

Tree protective fence / barrier (See Detail 1)

Tree protective fence / barrier (See Detail 4)

Documents/plans supplied by client for use in this drawing:  
 Topo Survey: Ref 1622  
 Master plan layout: 180809 L 02 02 A  
 Illustrative Masterplan

Accompanying documents which must be read in conjunction with this drawing:  
 05201 Tree Survey 10.06.21  
 05201 AIA Rev C 14.06.21

**Notes**

- All dimensions are in metres, unless otherwise stated.
- The original of this drawing was produced in colour, a monochrome version should therefore not be relied upon.



Client:	Mead Realisations Ltd
Project:	Land at Lynchmead Farm
Title:	Tree Protection Plan Rev C
Date:	20/06/2021
Drawn:	RF/DS
Scale:	1/500 @ A1 1/1000 @ A3
Checked:	DS

Dwg Ref: 05201 TPP Rev C 14.06.21

**ASPECT TREE CONSULTANCY**

Aspect Tree Consultancy Ltd.  
 Level 5 Hamlyn House  
 Mardle Way, Buckfastleigh  
 Devon TQ11 0NR

Tel: 01364 644822  
 www.fresh-aspect.com



- Key**
- Standard scaffold poles
  - Heavy gauge 2m tall galvanized tube and welded mesh infill panels
  - Panels secured to uprights and cross-members with wire ties
  - Ground level
  - Uprights driven into the ground until secure (minimum depth 0.6m)
  - Standard scaffold clamps

