

From: [Adam Clarke](#)
To: [Planning Support](#)
Subject: 23/P/0664/OUT
Date: 26 April 2023 15:16:13

Good Afternoon,

Please see below street lighting comments for the above planning application:

- Lanterns need to be Urbis Axia 3.1 (full spec to be determined by the lighting designer)
- Columns can be at 5m if this will help with ecology
- We would only want back shields installed where needed rather than on every column

Regards

Adam Clarke
Engineer

Highway Electrical & ITS
Place Directorate
North Somerset Council

Tel: 01934 426605 or 07824 085 740

E-Mail: Adam.Clarke@n-somerset.gov.uk

Post: Town Hall, Walliscote Grove Road, Weston-super-Mare, BS23 1UJ

Web: www.n-somerset.gov.uk